



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3122438-118-2022

MDE OFFICIAL CONTACTED: KATIE

DATA CALLED IN BY: MARVIN BAILEY

DATE: 02/10/2022 AT 12:30PM

WORK ORDER(S): 3122438 3122430

EST DATE AND TIME SSO BEGAN: 02/10/2022 07:20AM DURATION: 6.08 HRS

DATE AND TIME SSO ENDED: 02/10/2022 01:25PM

SOURCE-OVERFLOWING MH MH08001219 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 5400 54TH AVE 20781

COUNTY/PAGE/GRID: P 5410 B08 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 4,378 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 219M OVERFLOWING APPROXIMATELY 12GPM INTO THE ANACOSTIA RIVER, LOCATED IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 045U THROUGH 215M, TO 216M, A TOTAL OF 245FT, RELIEVING A GREASE AND WIPES OBSTRUCTION AT 245FT TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

*

CREWS WILL ATTEMPT A CCTV INSPECTION; HOWEVER, THIS IS A SIPHON SEGMENT AND MAY NOT BE CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

VISIBLE SOLIDS REMOVED

THE IMPACTED AREA WAS RESTORED WITH LIME AND HAY.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 5800 RIVERSIDE DRIVE.

UPDATE 02/15/22: CORRECTED OVERFLOWING MANHOLE ID FROM 08001217, TO 008001219

SIGNS POSTED: 20 POST DATE: 02/11/2022