



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3122669-072-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: ELBE L DAVIS

DATE: 02/11/2022 AT 09:18AM

WORK ORDER(S): 3122669 3122477

EST DATE AND TIME SSO BEGAN: 02/10/2022 10:53AM DURATION: 4.73 HRS

DATE AND TIME SSO ENDED: 02/10/2022 03:37PM

SOURCE-GRINDER PUMP SS04037323 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 8301 SWEENEY DR 20735

COUNTY/PAGE/GRID: P 5767 C06 TOWN/CITY: CLINTON

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 2 GAL

UPON RESPONSE TO REPAIR TO A WSSC-MAINTAINED GRINDER PUMP, A CONTRACT PLUMBER FOUND EVIDENCE THAT APPROXIMATELY TWO GALLONS OF SEWAGE HAD SPILLED ON THE GROUND NEAR THE GRINDER PUMP.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE GRINDER PUMP WAS REPAIRED. GRINDER PUMP SYSTEMS ARE NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES