



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3122985-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: JAMES V MALLORY

DATE: 02/14/2022 AT 08:33AM

WORK ORDER(S): 3122985 3122972

EST DATE AND TIME SSO BEGAN: 02/14/2022 06:41AM DURATION: 6.07 HRS

DATE AND TIME SSO ENDED: 02/14/2022 12:45PM

SOURCE-OVERFLOWING MH MH05024003 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 2739 GARFIELD AVE 20910

COUNTY/PAGE/GRID: M 5286 A10 TOWN/CITY: ROCK CREEK

CAUSE: DEBRIS

EST OVERFLOW VOLUME: 1,821 GAL

UPON ARRIVAL THE CREW FOUND MANHOLE 003M OVERFLOWING APROXIMATELY 5GPM, ENTERING NEARBY ROCK CREEK; IN THE ROCK CREEK BASIN. THE CREW JETTED FROM MANHOLE 005U TO 002M A TOTAL OF 510 FEET, AND RELIEVED PIECES OF A MANHOLE COVER IN THE CHANNEL OF MANHOLE 003M; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THREE BAGS OF LIME APPLIED.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 2730 GARFIELD AVE.

SIGNS POSTED: 5 POST DATE: 02/14/2022