



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3123097-073-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 02/14/2022 AT 04:27PM

WORK ORDER(S): 3123097 3123063

EST DATE AND TIME SSO BEGAN: 02/14/2022 01:21PM DURATION: 1.15 HRS

DATE AND TIME SSO ENDED: 02/14/2022 02:30PM

SOURCE-CLEAN OUT 00384496600 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 11206 HANNAH WAY 20774-1679

COUNTY/PAGE/GRID: P 5532 A08 TOWN/CITY: UPPER MARLBORO

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 3 GAL

UPON ARRIVAL THE CREW FOUND EVIDENCE THE PROPERTY LINE CLEANOUT HAD RECENTLY OVERFLOWED APPROXIMATELY 3 GALLONS TOTAL. THE CREW SNAKED FROM CLEANOUT AT PROPERTY LINE A TOTAL OF 15 FEET, AND RELIEVED SOFT UNKNOWN STOPPAGE AT 15 FEET. THE EVENT HAD ALREADY ENDED UPON THE CREW'S ARRIVAL.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

APPLIED LIME AND CLEANED AREA WITH VAC-CON.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 1 POST DATE: 02/14/2022