



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3124031-118-2022

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 02/21/2022 AT 12:55PM

WORK ORDER(S): 3124031 3124021

EST DATE AND TIME SSO BEGAN: 02/21/2022 10:48AM DURATION: 3.45 HRS
DATE AND TIME SSO ENDED: 02/21/2022 02:15PM

SOURCE-OVERFLOWING MH MH08056056 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 9091-93 BALTIMORE AVE 20782
COUNTY/PAGE/GRID: P 5288 B10 TOWN/CITY: COLLEGE PARK

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 1,035 GAL
UPON ARRIVAL CREW FOUND MANHOLE 056M OVERFLOWING APPROXIMATELY 5 GPM
INTO A NEARBY CREEK; IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED
FROM MANHOLE 051M TO 052U A TOTAL OF 336 FEET, AND RELIEVED A HARD
GREASE AND WIPES OBSTRUCTION AT APPROXIMATELY 250 FEET; ENDING THE
EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

ONE BAG OF LIME APPLIED.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 02/22/2022