



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3129300-118-2022

MDE OFFICIAL CONTACTED: CHRIS SHAFFAER

DATA CALLED IN BY: CAROLINA GONZALEZ RUIZ DATE: 03/08/2022 AT 10:45PM

WORK ORDER(S): 3129300 3129296

EST DATE AND TIME SSO BEGAN: 03/08/2022 08:36PM DURATION: 1.15 HRS
DATE AND TIME SSO ENDED: 03/08/2022 09:45PM

SOURCE-OVERFLOWING MH MH10072141 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 4 SUNCROFT CT 20904
COUNTY/PAGE/GRID: M 5166 K08 TOWN/CITY: KENSINGTON

CAUSE: GREASE EST OVERFLOW VOLUME: 35 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 141M OVERFLOWING APPROXIMATELY
1/2 GALLON PER MINUTE INTO A NEARBY STORM DRAIN; IN THE NORTHWEST
BRANCH BASIN. THE CREW USED PUSH RODS FROM MANHOLE 136U-138M A
TOTAL OF 42FT, AND RELIEVED A HEAVY GREASE OBSTRUCTION AT 42FT;
ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

USED FRESH WATER FROM JET TRUCK TO CLEAN AREA AROUND MH 141M.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 03/09/2022