



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3129674-109-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: ELBE L DAVIS

DATE: 03/11/2022 AT 03:50PM

WORK ORDER(S): 3129674 3129655

EST DATE AND TIME SSO BEGAN: 03/11/2022 05:54AM DURATION: 10.10 HRS

DATE AND TIME SSO ENDED: 03/11/2022 04:00PM

SOURCE-REPAIR SEWER MAIN SS18053093 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 850 CAPITOL HEIGHTS BLVD 20743

COUNTY/PAGE/GRID: P 5530 D10 TOWN/CITY: CAPITOL HEIGHTS

CAUSE: UNKNOWN

EST OVERFLOW VOLUME: 1,212 GAL

UPON ARRIVAL, THE CREW FOUND A BROKEN 6" SEWER MAIN OVERFLOWING AT  
2GPM. CONTRACTORS SET UP BYPASS PUMPING TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

\*CONTRACTORS REPLACED 4 FEET OF BROKEN 6" PIPE.

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT  
PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

SIGNS POSTED: 6 POST DATE: 03/12/2022