



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3130291-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 03/15/2022 AT 03:18PM

WORK ORDER(S): 3130291 3130289

EST DATE AND TIME SSO BEGAN: 03/15/2022 02:45PM DURATION: 8.42 HRS
DATE AND TIME SSO ENDED: 03/15/2022 11:10PM

SOURCE-OVERFLOWING MH MH09012057 WATER BODY AFFECTED-ANACOSTIA RIVER

CLOSEST STREET ADDRESS: 2800 52ND AVE 20781
COUNTY/PAGE/GRID: P 5530 A02 TOWN/CITY: HYATTSVILLE

CAUSE: WIPES EST OVERFLOW VOLUME: 1,010 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 057M OVERFLOWING AT A RATE OF
2GPM DIRECTLY INTO A RETENTION POND; IN THE LOWER ANACOSTIA BASIN.
DUE TO THE LOCATION OF THE MANHOLE, A WSSC CONTRACTOR SET UP
OVERPUMPING FROM MANHOLE 057M TO 015U; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 2820 52ND AVE.

SIGNS POSTED: 3 POST DATE: 03/17/2022