



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3130439-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: 4581

DATE: 03/16/2022 AT 03:15PM

WORK ORDER(S): 3130439 3130402

EST DATE AND TIME SSO BEGAN: 03/16/2022 10:33AM DURATION: 2.62 HRS

DATE AND TIME SSO ENDED: 03/16/2022 01:10PM

SOURCE-OVERFLOWING MH MH05167395 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 8100 PEPPER RIDGE WAY 20877

COUNTY/PAGE/GRID: M 5048 D07 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 786 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 395U OVERFLOWING APPROXIMATELY 5 GALLONS PER MINUTE GOING INTO A NEARBY CREEK. THE CREW JETTED THE MAINLINE FROM MANHOLE 011U TO MANHOLE 395U AND RELIEVED ROOTS, RAGS AND GREASE AT 205 FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

DRY WEATHER

VISIBLE SOLIDS, STREAM BANK

VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 8000 RW6 SPICEBERRY LANE.

SIGNS POSTED: 10 POST DATE: 03/16/2022