



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3130725-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA DATE: 03/18/2022 AT 10:30AM

WORK ORDER(S): 3130725 3130696

EST DATE AND TIME SSO BEGAN: 03/18/2022 08:19AM DURATION: 1.27 HRS
DATE AND TIME SSO ENDED: 03/18/2022 09:35AM

SOURCE-OVERFLOWING MH MH17010003 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 9304 HILLTOP CT 20708
COUNTY/PAGE/GRID: P 5169 E06 TOWN/CITY: LAUREL

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 229 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 003U OVERFLOWING AT A RATE OF 3GPM INTO A NEARBY STORM DRAIN; IN THE PARKWAY BRANCH BASIN. THE CREW JETTED FROM MANHOLE 002M TO 003U A TOTAL OF 158', AND HIT AND RELIEVED HEAVY WIPES AND ROOTS IN MANHOLE 003U; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THREE BAGS OF LIME WILL BE APPLIED TO AREA SURROUNDING MH003U.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 14500 LAUREL BOWIE RD.

SIGNS POSTED: 13 POST DATE: 03/18/2022