



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3131993-118-2022

MDE OFFICIAL CONTACTED: BRETT 131285

DATA CALLED IN BY: DON O DARKO

DATE: 03/27/2022 AT 09:45PM

WORK ORDER(S): 3131993 3131992

EST DATE AND TIME SSO BEGAN: 03/27/2022 04:31PM DURATION: 3.23 HRS

DATE AND TIME SSO ENDED: 03/27/2022 07:45PM

SOURCE-OVERFLOWING MH MH02016072 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 3018 GAZEBO CT 20904

COUNTY/PAGE/GRID: M 5287 J02 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 194 GAL

UPON ARRIVAL, THE CREW FOUND MANOLE 072M OVERFLOWING APPROXIMATELY
1 GPM. THE CREW JETTED FROM MANHOLE 031U TO 068M, A TOTAL OF 128
FEET, AND RELIEVED A HARD UNKNOWN BLOCKAGE AT 55 FEET TO END THE
EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/28/2022