



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3144487-118-2022

MDE OFFICIAL CONTACTED: VM @ 805PM

DATA CALLED IN BY: PARIS S JORDAN

DATE: 04/16/2022 AT 08:05PM

WORK ORDER(S): 3144487 3144478

EST DATE AND TIME SSO BEGAN: 04/16/2022 04:16PM DURATION: 3.57 HRS

DATE AND TIME SSO ENDED: 04/16/2022 07:50PM

SOURCE-OVERFLOWING MH MH05102021 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12200-415 BRAXFIELD CT 20852

COUNTY/PAGE/GRID: M 5285 D01 TOWN/CITY: ROCKVILLE

CAUSE: GREASE

EST OVERFLOW VOLUME: 428 GA

UPON ARRIVAL, THE CREW FOUND MANHOLE 021M OVERFLOWING AT APPROXIMATELY 2 GALLONS PER MINUTE INTO A NEARBY CREEK, IN THE ROCK CREEK BASIN. THE CREW RODDED FROM MANHOLE 020M TO MANHOLE 021M, A TOTAL OF 110 FEET, AND RELIEVED GREASE AT 70 FEET TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

SEWER FROM OVERFLOWING MANHOLE ENTERED INTO WOODS AND NEARBY CREEK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

LIME APPLIED ONTO IMPACTED GROUND

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 8 POST DATE: 04/16/2022