



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3145063-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: JAMES V MALLORY

DATE: 04/20/2022 AT 12:05PM

WORK ORDER(S): 3145063 3145027

EST DATE AND TIME SSO BEGAN: 04/20/2022 10:08AM DURATION: 3.20 HRS
DATE AND TIME SSO ENDED: 04/20/2022 01:20PM

SOURCE-OVERFLOWING MH MH11041051 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 4803 NEWMAN RD 20746
COUNTY/PAGE/GRID: P 5650 B09 TOWN/CITY: CAMP SPRINGS

CAUSE: GREASE EST OVERFLOW VOLUME: 96 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 051M OVERFLOWING AT APPROXIMATELY
0.5GPM INTO HENSON CREEK, IN THE BROAD CREEK BASIN. THE
CREW JETTED FROM MANHOLE 050M TO 051M, AND RELIEVED GREASE AT 75FT
TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

ONLY A TRICKLE OF THE OVERFLOW ENTERED INTO THE CREEK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

ONE BAG OF LIME APPLIED ONTO IMPACTED GROUND

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

ORIGINALLY REPORTED AS 4800BLK NEWMAN RD

SIGNS POSTED: 1 POST DATE: 04/20/2022