



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3154767-118-2022

MDE OFFICIAL CONTACTED: KENDRA DULLIS #132973

DATA CALLED IN BY: PATRICIA A HILL

DATE: 05/13/2022 AT 09:53PM

WORK ORDER(S): 3154767 3154765

EST DATE AND TIME SSO BEGAN: 05/13/2022 07:42PM DURATION: 3.80 HRS

DATE AND TIME SSO ENDED: 05/13/2022 11:30PM

SOURCE-OVERFLOWING MH MH08008067 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 7401 JEFFERSON CT 20784

COUNTY/PAGE/GRID: P 5410 H08 TOWN/CITY: LANDOVER HILLS

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 684 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 067M OVERFLOWING APPROXIMATELY 3 GALLONS PER MINUTE INTO A NEARBY CREEK, IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 067M TO 017U, A TOTAL OF 134FT, AND RELIEVED A GREASE, WIPES, AND ROOTS OBSTRUCTION AT 64FT; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR

PUBLIC ACCESS

VISIBLE SOLIDS, STREAM BANK

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES

INITIALLY REPORTED AT 7400 JEFFERSON CT.

SIGNS POSTED: 6 POST DATE: 05/14/2022