



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3158851-073-2022

MDE OFFICIAL CONTACTED: BRETT BOYCE

DATA CALLED IN BY: JAMES V MALLORY

DATE: 05/31/2022 AT 06:28AM

WORK ORDER(S): 3158851 3158838

EST DATE AND TIME SSO BEGAN: 05/30/2022 07:50PM DURATION: 1.17 HRS

DATE AND TIME SSO ENDED: 05/30/2022 09:00PM

SOURCE-CLEAN OUT 00187773700 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 3000 POWDER MILL RD 20783

COUNTY/PAGE/GRID: P 5287 G06 TOWN/CITY: HYATTSVILLE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 20 GAL

UPON ARRIVAL, THE WSSC CREW DISCOVERED MANHOLE 025M HOLDING AND EVIDENCE OF DISCHARGE FROM AN ON PROPERTY CLEAN OUT. THE CREW JETTED FROM MANHOLE 023M TO 024M A TOTAL OF 98 FEET RELIEVING A HARD UNKNOWN STOPAGE AT 80 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES