



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3162959-118-2022

MDE OFFICIAL CONTACTED: KATIE BAKER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 06/15/2022 AT 03:55PM

WORK ORDER(S): 3162959 3162917

EST DATE AND TIME SSO BEGAN: 06/15/2022 02:28PM DURATION: 1.87 HRS

DATE AND TIME SSO ENDED: 06/15/2022 04:20PM

SOURCE-OVERFLOWING MH MH06018018 WATER BODY AFFECTED-SLIGO CREEK

CLOSEST STREET ADDRESS: 7600 MAPLE AVE 20815

COUNTY/PAGE/GRID: M 5408 J03 TOWN/CITY: TAKOMA PARK

CAUSE: GREASE EST OVERFLOW VOLUME: 112 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 018M OVERFLOWING APPROXIMATELY 1 GALLON PER MINUTE INTO A NEARBY STORM DRAIN, IN THE SLIGO CREEK BASIN. THE CREW JETTED FROM MANHOLE 017U TO 018M, A TOTAL OF 153FT, AND RELIEVED A HEAVY GREASE OBSTRUCTION; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 9 POST DATE: 06/15/2022