



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3162896-118-2022

MDE OFFICIAL CONTACTED: KATIE BAKER

DATA CALLED IN BY: MARK A ALEXANDER

DATE: 06/15/2022 AT 04:28PM

WORK ORDER(S): 3162896 3162868

EST DATE AND TIME SSO BEGAN: 06/15/2022 11:03AM DURATION: 2.87 HRS

DATE AND TIME SSO ENDED: 06/15/2022 01:55PM

SOURCE-OVERFLOWING MH MH04025045 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 4710 JEAN MARIE DR 20744

COUNTY/PAGE/GRID: P 5766 B05 TOWN/CITY: FORT WASHINGTON

CAUSE: ROOTS EST OVERFLOW VOLUME: 172 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 045M OVERFLOWING 1GPM ONTO THE GRASS. THE CREW JETTED FROM MANHOLE 043M-045M, A TOTAL 90FT, RELIEVING HEAVY ROOTS @ 90FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT