



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3164959-118-2022

MDE OFFICIAL CONTACTED: AMANDA

DATA CALLED IN BY: PATRICIA A HILL

DATE: 06/29/2022 AT 06:10PM

WORK ORDER(S): 3164959 3164948

EST DATE AND TIME SSO BEGAN: 06/29/2022 04:19PM DURATION: 2.68 HRS

DATE AND TIME SSO ENDED: 06/29/2022 07:00PM

SOURCE-OVERFLOWING MH MH10051056 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 3700 ROSSMOOR BLVD 20906

COUNTY/PAGE/GRID: M 5165 H04 TOWN/CITY: SILVER SPRING

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 804 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 056M OVERFLOWING ONTO A GRASSY AREA. THE CREW JETTED FROM MANHOLE 055U TO 056M, A TOTAL OF 359FT, RELIEVING HEAVY ROOTS AND GREASE AT 355FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT

INITIALLY REPORTED AS 10 FINSBURY PARK CT.

SIGNS POSTED: 2 POST DATE: 06/30/2022