



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3168142-109-2022

MDE OFFICIAL CONTACTED: EVELYN STRAVROU

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 07/12/2022 AT 03:14PM

WORK ORDER(S): 3168142 3168127

EST DATE AND TIME SSO BEGAN: 07/12/2022 01:57PM DURATION: 10.05 HRS

DATE AND TIME SSO ENDED: 07/13/2022 12:00AM

SOURCE-REPAIR SEWER MAIN SS07065010 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 8500 RIVER RD 20817

COUNTY/PAGE/GRID: M 5406 B01 TOWN/CITY: BETHESDA

CAUSE: UNKNOWN

EST OVERFLOW VOLUME: 603 GAL

UPON ARRIVAL, THE CREW FOUND BROKEN SEWER PIPE AT 5 FEET DOWNSTREAM OF MANHOLE 07065010M, LEAKING INTO AN ADJACENT POND AT APPROXIMATELY 1 GALLON PER MINUTE. A WSSC CONTRACTOR SET UP OVERPUMPING FROM MH# 07065010M TO MH# 07065008U TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

OVERFLOW IN POND DILUTED DUE TO RAIN AFTER THE EVENT. OVERPUMPING TO STAY IN PLACE UNTIL WSSC CONTRACTOR PERFORM REPAIR ON THE BROKEN PIPE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

INITIALLY REPORTED AS 8500BLK RW BRADLEY BLVD

SIGNS POSTED: 6 POST DATE: 07/13/2022