



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3170341-118-2022

MDE OFFICIAL CONTACTED: KENDRA DUKES #135230

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 07/20/2022 AT 09:09PM

WORK ORDER(S): 3170341 3170312

EST DATE AND TIME SSO BEGAN: 07/20/2022 05:33PM DURATION: 4.45 HRS
DATE AND TIME SSO ENDED: 07/20/2022 10:00PM

SOURCE-OVERFLOWING MH MH29007138 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 4411 DARIO RD 20772
COUNTY/PAGE/GRID: P 5653 F08 TOWN/CITY: UPPER MARLBORO

CAUSE: GREASE EST OVERFLOW VOLUME: 267 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 138M OVERFLOWING APPROXIMATELY
1 GALLON PER MINUTE INTO A NEARBY CREEK, IN THE PATUXENT CENTER
BASIN. THE CREW JETTED FROM MANHOLE 136U TO 138M A TOTAL OF 125 FEET,
AND RELIEVED A HEAVY GREASE OBSTRUCTION TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE	LIME
---------------------------	------

LIME SPREAD ON IMPACTED GROUND AROUND THE MANHOLE ON 07/21/2022.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES	MD DEPARTMENT OF ENVIRONMENT
PG COUNTY HEALTH DEPT	

SIGNS POSTED: 3 POST DATE: 07/21/2022