



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3189409-118-2022

MDE OFFICIAL CONTACTED: JOSHUA SARCHIAPONE

DATA CALLED IN BY: JAMES V MALLORY

DATE: 09/25/2022 AT 03:30PM

WORK ORDER(S): 3189409 3189405

EST DATE AND TIME SSO BEGAN: 09/25/2022 01:24PM DURATION: 2.35 HRS
DATE AND TIME SSO ENDED: 09/25/2022 03:45PM

SOURCE-OVERFLOWING MH MH11056092 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 3447 DONNELL DR 20747
COUNTY/PAGE/GRID: P 5650 J05 TOWN/CITY: FORESTVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 141 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 92M OVERFLOWING APPROXIMATELY
1GPM IN A PARKING LOT, THEN INTO AN UNKNOWN TRIBUTARY TO BROAD CREEK.
THE CREW JETTED FROM MANHOLE 92M-91M, FOR A TOTAL OF 168FT, AND
RELIEVED GREASE AT 140FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS
PUBLIC USE OBSERVED	

DUE TO RAINFALL DURING THE EVENT, THERE WAS NO NEED TO WASH DOWN THE
PARKING LOT.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT	PG COUNTY MUNICIPALITIES
MD DEPARTMENT OF ENVIRONMENT	

ORIGINALLY REPORTED AS 3443 DONNELL DRIVE

SIGNS POSTED: 2 POST DATE: 09/25/2022