



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3190505-118-2022

MDE OFFICIAL CONTACTED: JOSH CAIN

DATA CALLED IN BY: MARVIN BAILEY

DATE: 09/30/2022 AT 05:08PM

WORK ORDER(S): 3190505 3190483

EST DATE AND TIME SSO BEGAN: 09/30/2022 09:46AM DURATION: 1.48 HRS  
DATE AND TIME SSO ENDED: 09/30/2022 11:15AM

SOURCE-OVERFLOWING MH MH08037050 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6200 WESTCHESTER PK DR 20740  
COUNTY/PAGE/GRID: P 5410 G02 TOWN/CITY: COLLEGE PARK

CAUSE: WIPES EST OVERFLOW VOLUME: 178 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 050N OVERFLOWING AT  
APPROXIMATELY 2 GALLONS PER MINUTE INTO A NEARBY CREEK,  
IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 049M  
TO 050N, A TOTAL OF 230FT, AND RELIEVED WIPES AT 165FT TO END  
THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DISCOLORATION DRY WEATHER  
NOTICEABLE ODOR PUBLIC ACCESS  
PUBLIC USE OBSERVED VISIBLE SOLIDS, STREAM BANK  
VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 5 POST DATE: 09/30/2022