



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3197704-118-2022

MDE OFFICIAL CONTACTED: JOSH/REF#138095

DATA CALLED IN BY: 4581

DATE: 10/23/2022 AT 01:20PM

WORK ORDER(S): 3197704 3197698

EST DATE AND TIME SSO BEGAN: 10/23/2022 11:51AM DURATION: 1.90 HRS
DATE AND TIME SSO ENDED: 10/23/2022 01:45PM

SOURCE-OVERFLOWING MH MH14070047 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 15306 GOVERNORS PARK LN 20773
COUNTY/PAGE/GRID: P 5653 B07 TOWN/CITY: UPPER MARLBORO

CAUSE: DEBRIS EST OVERFLOW VOLUME: 228 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 047M OVERFLOWING AT 2 GPM
IN THE WESTERN BRANCH BASIN. THE CREW FOUND THE TOILET BOWL IN THE
DROP CONNECTION HAD COLLAPSED. THE CREW JETTED FROM MANHOLE 045M TO
046U, A TOTAL OF 45FT, AND RELIEVED A HARD UNKNOWN OBJECT AT 44FT TO END
THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

SIGNS POSTED: 4 POST DATE: 10/23/2022