



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3208129-073-2022

MDE OFFICIAL CONTACTED: CHRIS #138961

DATA CALLED IN BY: PATRICIA A HILL

DATE: 11/18/2022 AT 07:56PM

WORK ORDER(S): 3208129 3208115

EST DATE AND TIME SSO BEGAN: 11/18/2022 05:28PM DURATION: 6.87 HRS

DATE AND TIME SSO ENDED: 11/19/2022 12:20AM

SOURCE-CLEAN OUT 00247457500 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 4308 HOWARD RD 20705

COUNTY/PAGE/GRID: P 5288 C04 TOWN/CITY: BELTSVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 412 GAL

UPON ARRIVAL THE CREW FOUND THE PROPERTY LINE CLEANOUT
OVERFLOWING 1GPM , INTO GRASS AND A NEARBY STORM DRAIN
THAT ENTERS INDIAN CREEK. THE CREW JETTED FROM MANHOLE 142M TO
143M HIT AND RELIEVED HARD ROOTS AT 45FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 1 POST DATE: 11/19/2022