



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3210099-118-2022

MDE OFFICIAL CONTACTED: AMANDA

DATA CALLED IN BY: PATRICIA A HILL DATE: 11/30/2022 AT 06:44PM

WORK ORDER(S): 3210099 3210091

EST DATE AND TIME SSO BEGAN: 11/30/2022 05:08PM DURATION: 3.12 HRS
DATE AND TIME SSO ENDED: 11/30/2022 08:15PM

SOURCE-OVERFLOWING MH MH15019058 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 19033 STEDWICK DR 20886
COUNTY/PAGE/GRID: M 5047 G03 TOWN/CITY: MONTGOMERY VILLAGE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 187 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 058U OVERFLOWING AT
APPROXIMATELY 1GPM ONTO A GRASSY AREA NEAR A BIKE PATH.
THE CREW JETTED FROM MANHOLE 056U TO MANHOLE 058U A TOTAL OF 251
FEET, AND HIT AND RELIEVED HEAVY GREASE AND WIPES AT 124 FEET
UPSTREAM OF MANHOLE 056U, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

A MAINTENANCE CREW WILL RETURN TO SPREAD LIME.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT