



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3211708-118-2022

MDE OFFICIAL CONTACTED: MS. EVELYN

DATA CALLED IN BY: 4581 DATE: 12/05/2022 AT 01:00PM

WORK ORDER(S): 3211708 3211696

EST DATE AND TIME SSO BEGAN: 12/05/2022 12:14PM DURATION: 1.60 HRS
DATE AND TIME SSO ENDED: 12/05/2022 01:50PM

SOURCE-OVERFLOWING MH MH13006229 WATER BODY AFFECTED-MUDDY BRANCH

CLOSEST STREET ADDRESS: 14219 MANIFEST WAY 20878
COUNTY/PAGE/GRID: M 5163 B06 TOWN/CITY: GAITHERSBURG

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 480 GAL
UPON THE CREWS ARRIVAL, MANHOLE 229M WAS OVERFLOWING AT APPROXIMATELY
5GPM. THE CREW JETTED FROM MANHOLE 228U TO 229M, A TOTAL OF 108FT,
AND RELIEVED A HEAVY GREASE AND WIPES OBSTRUCTION AT 80FT; ENDING
THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME ON THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 5 POST DATE: 12/05/2022