



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3187242-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 09/13/2022 AT 02:18PM

WORK ORDER(S): 3187242 3187228

EST DATE AND TIME SSO BEGAN: 09/13/2022 12:32PM DURATION: 2.72 HRS

DATE AND TIME SSO ENDED: 09/13/2022 03:15PM

SOURCE-OVERFLOWING MH MH02016047 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 11785 BELTSVILLE DR 20705

COUNTY/PAGE/GRID: P 5288 A02 TOWN/CITY: BELTSVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 816 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 047M WAS OVERFLOWING AT APPROXIMATELY 5GPM INTO A NEARBY POND, IN THE PAINT BRANCH BASIN. THE CREW JETTED FROM MANHOLE 006U TO 047M, A TOTAL OF 148 FEET, AND RELIEVED ROOTS AT 103 FEET TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 11741 BELTSVILLE DRIVE

SIGNS POSTED: 2 POST DATE: 09/13/2022