



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3207279-118-2022

MDE OFFICIAL CONTACTED: JOSHUA SARCHIAPONE

DATA CALLED IN BY: DON O DARKO

DATE: 11/14/2022 AT 05:30PM

WORK ORDER(S): 3207279 3207252

EST DATE AND TIME SSO BEGAN: 11/14/2022 02:30PM DURATION: 3.50 HRS  
DATE AND TIME SSO ENDED: 11/14/2022 06:00PM

SOURCE-OVERFLOWING MH MH05142044 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 114 DERWOOD CIR 20850  
COUNTY/PAGE/GRID: M 5164 F04 TOWN/CITY: ROCKVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 210 GAL  
THE RESPONDING CREW FOUND MANHOLE #044U OVERFLOWING AT A RATE OF 1  
GALLON A MINUTE. THE CREW JETTED THE MAINLINE FROM MANHOLE #043M  
AND REMOVED RAGS, WIPES, AND GREASE AT 90 FEET TO END THE EVENT.

### IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	NOTICEABLE ODOR
PUBLIC ACCESS	PUBLIC USE OBSERVED

SEWAGE ENTERED AN UNNAMED TRIBUTARY OF ROCK CREEK THROUGH  
A STORMDRAIN NEAR MANHOLE #044U.

### STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

### MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE	RAKED AREA
VISIBLE SOLIDS REMOVED	LIME

A PORTION OF THE OVERFLOW ENTERED A STORMDRAIN IN THE ROCK  
CREEK BASIN, THE REMAINDER WAS FLUSHED BACK INTO THE MANHOLE  
AND IMPACTED GROUND AREAS WERE RAKED AND LIMED.

### NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES	

ORIGINALLY REPORTED AS 104 DERWOOD CIRCLE

SIGNS POSTED: 1 POST DATE: 11/14/2022