



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3222089-118-2023

MDE OFFICIAL CONTACTED: EVELYN

DATA CALLED IN BY: PARIS S JORDAN

DATE: 01/19/2023 AT 11:40AM

WORK ORDER(S): 3222089 3222056

EST DATE AND TIME SSO BEGAN: 01/19/2023 08:20AM DURATION: 2.10 HRS

DATE AND TIME SSO ENDED: 01/19/2023 10:30AM

SOURCE-OVERFLOWING MH MH05018015 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 4403 ELM ST 20815

COUNTY/PAGE/GRID: M 5407 F03 TOWN/CITY: CHEVY CHASE

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 1,300 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 015M OVERFLOWING AT A RATE OF 10GPM. THE CREW JETTED FROM 015M TO 014M, A TOTAL OF 400FT, HIT AND RELIEVED ROOTS AND GREASE OBSTRUCTION AT 325FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 2 POST DATE: 01/19/2023