



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3228271-118-2023

MDE OFFICIAL CONTACTED: KENDRA INCIDENT#141624

DATA CALLED IN BY: 4581

DATE: 02/05/2023 AT 12:32PM

WORK ORDER(S): 3228271 3228265

EST DATE AND TIME SSO BEGAN: 02/05/2023 11:16AM DURATION: 1.10 HRS

DATE AND TIME SSO ENDED: 02/05/2023 12:22PM

SOURCE-OVERFLOWING MH MH11015116 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 308 CORLA DR 20745

COUNTY/PAGE/GRID: P 5764 K05 TOWN/CITY: OXON HILL

CAUSE: GREASE EST OVERFLOW VOLUME: 198 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 116M OVERFLOWING APPROXIMATELY 3GPM, GOING INTO AN UNKNOWN TRIBUTARY THAT ENTERS BROAD CREEK. THE CREW JETTED FROM MANHOLE 115M TO 116M A TOTAL OF 162FT, AND HIT AND RELIEVED HARD GREASE AT 75FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME	RAKED AREA
------	------------

ON 02/06/2023 THE CREW RAKED THE AREA AND SPREAD ONE BAG OF LIME AND ONE BALE OF STRAW IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES	

SIGNS POSTED: 4 POST DATE: 02/06/2023