



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3228681-118-2023

MDE OFFICIAL CONTACTED: PATRICK CAMERA

DATA CALLED IN BY: DON O DARKO

DATE: 02/07/2023 AT 06:23PM

WORK ORDER(S): 3228681 3228657

EST DATE AND TIME SSO BEGAN: 02/07/2023 02:04PM DURATION: 1.93 HRS
DATE AND TIME SSO ENDED: 02/07/2023 04:00PM

SOURCE-OVERFLOWING MH MH07009004 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 6414 83RD PL 20818
COUNTY/PAGE/GRID: M 5406 C05 TOWN/CITY: CABIN JOHN

CAUSE: ROOTS EST OVERFLOW VOLUME: 116 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 004M OVERFLOWING APPROXIMATELY 1GPM INTO A GRASSY AREA AND A NEARBY STORM DRAIN IN THE CABIN JOHN BASIN. THE CREW JETTED FROM MANHOLE 003M TO 004M, A TOTAL OF 306FT, AND HIT AND RELIEVED A HEAVY ROOT OBSTRUCTION AT 130FT, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW POSTED 10 SIGNS FROM MANHOLE 004M TO THE CLARA BARTON PARKWAY. THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

SIGNS POSTED: 10 POST DATE: 02/07/2023