



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3231713-118-2023

MDE OFFICIAL CONTACTED: REGAN MERCER

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 02/23/2023 AT 06:54PM

WORK ORDER(S): 3231713 3231700

EST DATE AND TIME SSO BEGAN: 02/23/2023 04:27PM DURATION: 4.55 HRS
DATE AND TIME SSO ENDED: 02/23/2023 09:00PM

SOURCE-OVERFLOWING MH MH29007264 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 17103 USHER PL 20772
COUNTY/PAGE/GRID: P 5653 G07 TOWN/CITY: UPPER MARLBORO

CAUSE: WIPES EST OVERFLOW VOLUME: 546 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 264M OVERFLOWING AT APPROXIMATELY
2 GPM, ONTO A GRASSY AREA AND INTO A NEARBY STORM DRAIN THAT ENTERS THE
PATUXENT CENTER BASIN. THE CREW JETTED FROM MANHOLE 265U TO 264M, AND HIT
AND RELIEVED WIPES AT 118'FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE RAKED AREA
LIME

AFFECTED GRASS AREA TREATED WITH LIME, STREET WAS WASHED DOWN AND FLUSHED
BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 02/23/2023