



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3232124-075-2023

MDE OFFICIAL CONTACTED: JOANNE HOHMAN

DATA CALLED IN BY: ELBE L DAVIS

DATE: 02/27/2023 AT 10:20PM

WORK ORDER(S): 3232124 3231964

EST DATE AND TIME SSO BEGAN: 02/26/2023 08:00AM DURATION: 37.25 HRS
DATE AND TIME SSO ENDED: 02/27/2023 09:15PM

SOURCE-AIR REL VLV/FORCE M SS21999094 WATER BODY AFFECTED-MATTAWOMAN

CLOSEST STREET ADDRESS: 16410 ACCOLAWN RD 20607
COUNTY/PAGE/GRID: P 5996 D03 TOWN/CITY: ACCOKEEK

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 559 GAL
UPON ARRIVAL, THE CREW FOUND WATER SURFACING FROM THE STREET AND WATER
PONDING IN A YARD. THE CREW WAS UNABLE TO DETERMINE THE SOURCE. THE
CREW TOOK WATER SAMPLES TO PISCATAWAY PLANT AND VERIFIED IT WAS
SEWER. ON 2/27/23 THE CREW DUG DOWN TO THE FORCE MAIN AND PLACED A
FERNCO COUPLING ON THE MAIN, ENDING THE EVENT. NO WATERWAY AFFECTED.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED FROM A FORCE MAIN AND IS THEREFORE NOT CCTV'ABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 02/27/2023