



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3232449-073-2023

MDE OFFICIAL CONTACTED: EVELYN STRAVROU

DATA CALLED IN BY: BRANDON T MCCREA DATE: 02/28/2023 AT 02:35PM

WORK ORDER(S): 3232449 3232393

EST DATE AND TIME SSO BEGAN: 02/28/2023 12:39PM DURATION: 1.35 HRS
DATE AND TIME SSO ENDED: 02/28/2023 02:00PM

SOURCE-CLEAN OUT 00069837300 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 6525 BRADLEY BLVD 20817
COUNTY/PAGE/GRID: M 5406 J01 TOWN/CITY: BETHESDA

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 10 GAL

UPON ARRIVAL, THE CREW FOUND EVIDENCE OF AN OVERFLOW THAT HAD ALREADY STOPPED. THE CREW ESTIMATED THE TOTAL VOLUME TO BE 10 GALLONS. A WSSC PLUMBER SNAKED THE CLEANOUT AND RELIEVED A HARD UNKNOWN AT 6FT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 02/28/2023