



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3235170-118-2023

MDE OFFICIAL CONTACTED: WOODWARD

DATA CALLED IN BY: PATRICIA A HILL

DATE: 03/09/2023 AT 09:23PM

WORK ORDER(S): 3235170 3235093

EST DATE AND TIME SSO BEGAN: 03/09/2023 02:05PM DURATION: 3.08 HRS

DATE AND TIME SSO ENDED: 03/09/2023 05:10PM

SOURCE-OVERFLOWING MH MH08058128 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6301 IVY LN 20770

COUNTY/PAGE/GRID: P 5288 G09 TOWN/CITY: GREENBELT

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 924 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 128M OVERFLOWING APPROXIMATELY 5GPM,  
ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO AN UNKNOWN  
HOLDING POND THAT ENTERS NORTHEAST BRANCH. THE CREW JETTED FROM  
MANHOLE 127M TO 145U, A TOTAL OF 400FT, HIT AND RELIEVED RAGS AND  
GREASE AT 105FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA

TWO BAGS OF LIME SPREAD IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 6300 CHERRYWOOD LANE.

SIGNS POSTED: 2 POST DATE: 03/10/2023