



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3235773-118-2023

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA DATE: 03/15/2023 AT 12:12PM

WORK ORDER(S): 3235773 3235738

EST DATE AND TIME SSO BEGAN: 03/15/2023 08:58AM DURATION: 3.50 HRS  
DATE AND TIME SSO ENDED: 03/15/2023 12:28PM

SOURCE-OVERFLOWING MH MH14038064 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 5513 MANOR PARK DR 20772  
COUNTY/PAGE/GRID: P 5651 G09 TOWN/CITY: UPPER MARLBORO

CAUSE: GREASE EST OVERFLOW VOLUME: 420 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 064M OVERFLOWING APPROXIMATELY  
2GPM ONTO GRAVEL AND INTO A TRIBUTARY OF WESTERN BRANCH. MANHOLES  
965M, 063M, 062U, AND 061U WERE SURCHARGED. THE CREW JETTED FROM  
MANHOLE 060U TO 061U A TOTAL OF 332FT, AND HIT AND RELIEVED A GREASE  
AND SOFT UNKNOWN BLOCKAGE AT 38FT, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
CLEAR WATER DISCHARGE ONLY, THE AREA WAS WASHED DOWN.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 03/15/2023