



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3224320-073-2023

MDE OFFICIAL CONTACTED: PATRICK INC 141391

DATA CALLED IN BY: PATRICIA A HILL

DATE: 01/28/2023 AT 09:18PM

WORK ORDER(S): 3224320 3224304

EST DATE AND TIME SSO BEGAN: 01/28/2023 03:08PM DURATION: 4.87 HRS

DATE AND TIME SSO ENDED: 01/28/2023 08:00PM

SOURCE-CLEAN OUT 00497445700 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 21936 FREDERICK RD 20841

COUNTY/PAGE/GRID: M 4928 K06 TOWN/CITY: BOYDS

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 292 GAL

UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING APPROXIMATELY 1 GPM ONTO AN IMPERVIOUS SURFACE AND INTO A STORM DRAIN THAT LEADS TO A TRIBUTARY OF LITTLE SENECA CREEK. THE CREW FLUSHED THE FORCED MAIN FROM MANHOLE 164R FOR 30 MINUTES, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

THIS SEGMENT ON A FORCE MAIN AND IS THEREFORE NOT CCTV'ABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 1 POST DATE: 01/28/2023