



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3237915-118-2023

MDE OFFICIAL CONTACTED: EVELYN STAROU

DATA CALLED IN BY: 4581

DATE: 03/30/2023 AT 11:50AM

WORK ORDER(S): 3237915 3237879

EST DATE AND TIME SSO BEGAN: 03/30/2023 08:34AM DURATION: 2.18 HRS

DATE AND TIME SSO ENDED: 03/30/2023 10:45AM

SOURCE-OVERFLOWING MH MH02021014 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 12533 MONTCLAIR DR 20904

COUNTY/PAGE/GRID: M 5287 B01 TOWN/CITY: SILVER SPRING

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 131 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 014U OVERFLOWING APPROXIMATELY 1GPM INTO A NEARBY STORM DRAIN IN THE PAINT BRANCH BASIN. THE CREW JETTED FROM MANHOLE 014U TO 013U, A TOTAL OF 199FT, AND HIT AND RELIEVED A HEAVY GREASE AND WIPES OBSTRUCTION AT 1FT, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC USE OBSERVED

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

RAKED AREA

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 12921 BUCKEYE DRIVE.

SIGNS POSTED: 3 POST DATE: 03/30/2023