



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3240863-118-2023

MDE OFFICIAL CONTACTED: PATRICK KAMMER

DATA CALLED IN BY: JAMES V MALLORY

DATE: 04/09/2023 AT 11:45AM

WORK ORDER(S): 3240863 3240860

EST DATE AND TIME SSO BEGAN: 04/09/2023 09:14AM DURATION: 3.02 HRS

DATE AND TIME SSO ENDED: 04/09/2023 12:15PM

SOURCE-OVERFLOWING MH MH08069733 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 7328 CALICO ROCK LANDING 20705

COUNTY/PAGE/GRID: P 5168 K10 TOWN/CITY: BELTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 906 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 733N OVERFLOWING APPROXIMATELY 5 GPM INTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A NEARBY STORM DRAIN THAT ENTERS NORTHEAST BRANCH. THE CREW JETTED FROM MANHOLE 694M TO MANHOLE 721U, A TOTAL OF 135', AND HIT AND RELIEVED A HEAVY GREASE AND WIPES BLOCKAGE AT 134', ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND MANHOLE 733N.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 8 POST DATE: 04/09/2023