



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3242771-118-2023

MDE OFFICIAL CONTACTED: REGAN MARCER

DATA CALLED IN BY: CAROLINA GONZALEZ RUIZ DATE: 04/20/2023 AT 09:25PM

WORK ORDER(S): 3242771 3242756

EST DATE AND TIME SSO BEGAN: 04/20/2023 06:56PM DURATION: 5.07 HRS
DATE AND TIME SSO ENDED: 04/21/2023 12:00AM

SOURCE-OVERFLOWING MH MH10019092 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 5001 37TH AVE 20782
COUNTY/PAGE/GRID: P 5409 G08 TOWN/CITY: BRENTWOOD

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 152 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 092M OVERFLOWING APPROXIMATELY
0.5 GPM, GOING INTO THE GRASSY AREA AROUND THE MANHOLE. THE
CREW JETTED FROM MANHOLE 092M TO 007T A TOTAL OF 240FEET, AND HIT AND
RELIEVED A GREASE AND WIPES BLOCKAGE AT 85FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

| | |
|---------------|---------------------|
| DISCOLORATION | NOTICEABLE ODOR |
| PUBLIC ACCESS | PUBLIC USE OBSERVED |

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

| | |
|---------------------------|------|
| FLUSHED BACK INTO MANHOLE | LIME |
|---------------------------|------|

NOTIFICATIONS MADE:

| | |
|------------------------------|-----------------------|
| MD DEPARTMENT OF ENVIRONMENT | PG COUNTY HEALTH DEPT |
| PG COUNTY MUNICIPALITIES | |

SIGNS POSTED: 10 POST DATE: 04/21/2023