



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3254638-118-2023

MDE OFFICIAL CONTACTED: EVELYN

DATA CALLED IN BY: PARIS S JORDAN

DATE: 05/19/2023 AT 04:15PM

WORK ORDER(S): 3254638 3254623

EST DATE AND TIME SSO BEGAN: 05/19/2023 12:03PM DURATION: 1.45 HRS

DATE AND TIME SSO ENDED: 05/19/2023 01:30PM

SOURCE-OVERFLOWING MH MH14126155 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 1-91 WATKINS PARK DR 20774

COUNTY/PAGE/GRID: P 5532 D07 TOWN/CITY: UPPER MARLBORO

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 87 GAL

UPON ARRIVAL, THE CREW FOUND MH155M OVERFLOWING INTO A GRASSY AREA AT APPROXIMATELY 1GPM. THE CREW JETTED FROM MH154M TO 155M, A TOTAL OF 400FT, AND HIT AND RELIEVED A HEAVY GREASE AND WIPES BLOCKAGE AT 40FT, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT  
PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

THIS EVENT WAS ORIGINALLY REPORTED AS 10 WATKINS PARK DRIVE.

SIGNS POSTED: 2 POST DATE: 05/19/2023