



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3258716-073-2023

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: MARGARET K CEASAR

DATE: 06/07/2023 AT 10:05PM

WORK ORDER(S): 3258716 3258715

EST DATE AND TIME SSO BEGAN: 06/07/2023 08:14PM DURATION: 2.77 HRS

DATE AND TIME SSO ENDED: 06/07/2023 11:00PM

SOURCE-CLEAN OUT 00121454300 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 2311 SHADYSIDE AVE 20746

COUNTY/PAGE/GRID: P 5650 A03 TOWN/CITY: SUITLAND

CAUSE: GREASE

EST OVERFLOW VOLUME: 166 GAL

UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING APPROXIMATELY 1GPM, INTO THE GRASSY AREA AROUND THE CLEANOUT AND INTO A STORM DRAIN IN THE OXON RUN BASIN. THE CREW JETTED FROM MANHOLE 009M TO 010M, A TOTAL OF 320', AND HIT AND RELIEVED A MEDIUM GREASE OBSTRUCTION AT 40FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA

VISIBLE SOLIDS REMOVED

LIME

THE CREW SPREAD LIME ON THE GRASSY AREA AROUND THE CLEANOUT.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

SIGNS POSTED: 1 POST DATE: 06/07/2023