



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3259424-118-2023

MDE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: CAROLINA GONZALEZ RUIZ DATE: 06/13/2023 AT 09:20PM

WORK ORDER(S): 3259424 3259305

EST DATE AND TIME SSO BEGAN: 06/13/2023 09:10AM DURATION: 12.83 HRS
DATE AND TIME SSO ENDED: 06/13/2023 10:00PM

SOURCE-OVERFLOWING MH MH14092080 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 8218 STEVE DR 20747
COUNTY/PAGE/GRID: P 5651 B03 TOWN/CITY: FORESTVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 770 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 080U OVERFLOWING APPROXIMATELY
1GPM, INTO A NEARBY STORM DRAIN IN THE WESTERN BRANCH BASIN. THE CREW
JETTED FROM MANHOLE 008U TO 080U, A TOTAL OF 171FT, AND RELIEVED A
MEDIUM GREASE OBSTRUCTION AT 128FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

THE CREW FLUSHED THE POOLED SEWAGE BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 06/13/2023