



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3270501-118-2023

MDE OFFICIAL CONTACTED: JAMES

DATA CALLED IN BY: PATRICIA A HILL

DATE: 07/20/2023 AT 08:00PM

WORK ORDER(S): 3270501 3270467

EST DATE AND TIME SSO BEGAN: 07/20/2023 05:35PM DURATION: 2.08 HRS

DATE AND TIME SSO ENDED: 07/20/2023 07:40PM

SOURCE-OVERFLOWING MH MH12015134 WATER BODY AFFECTED-LITTLE FALLS

CLOSEST STREET ADDRESS: 5617 WARWICK PL 20815

COUNTY/PAGE/GRID: M 5407 F06 TOWN/CITY: CHEVY CHASE

CAUSE: GREASE EST OVERFLOW VOLUME: 624 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 134M OVERFLOWING 5 GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A TRIBUTARY OF LITTLE FALLS BASIN. THE CREW JETTED FROM MANHOLE 135U TO 025U A TOTAL OF 462', AND HIT AND REMOVED GREASE @ 465', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

THIS EVENT WAS ORIGINALLY REPORTED AS 5703 RW1 WARWICK PLACE.

SIGNS POSTED: 5 POST DATE: 07/20/2023