



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3278083-118-2023

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 08/17/2023 AT 06:25PM

WORK ORDER(S): 3278083 3278048

EST DATE AND TIME SSO BEGAN: 08/17/2023 10:02AM DURATION: 6.47 HRS
DATE AND TIME SSO ENDED: 08/17/2023 04:30PM

SOURCE-OVERFLOWING MH MH14167011 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 9710 CANARY CT 20774
COUNTY/PAGE/GRID: P 5531 G01 TOWN/CITY: UPPER MARLBORO

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 1,941 GAL
UPON ARRIVAL, THE CREW FOUND MH#011 OVERFLOWING AT 5GPM ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A TRIBUTARY OF WESTERN BRANCH. THE CREW JETTED FROM MH#010 TO MH#011 A TOTAL OF 217', AND RELIEVED A HEAVY GREASE AND WIPES BLOCKAGE AT 180', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY MUNICIPALITIES MD DEPARTMENT OF ENVIRONMENT
PG COUNTY HEALTH DEPT

THIS EVENT WAS ORIGINALLY REPORTED AS 9801 OLD SPRING ROAD.

SIGNS POSTED: 10 POST DATE: 08/18/2023