



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3285426-073-2023

MDE OFFICIAL CONTACTED: KENDRA DUKES

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 09/06/2023 AT 09:05PM

WORK ORDER(S): 3285426 3285398

EST DATE AND TIME SSO BEGAN: 09/06/2023 07:34PM DURATION: 1.43 HRS

DATE AND TIME SSO ENDED: 09/06/2023 09:00PM

SOURCE-CLEAN OUT 00130595200 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 6236 OXON HILL RD 20745

COUNTY/PAGE/GRID: P 5765 C02 TOWN/CITY: OXON HILL

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 43 GAL

UPON ARRIVAL, THE INSPECTOR FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING 0.5GPM ONTO A GRASSY AREA. THE INSPECTOR DIRECTED THE OCCUPANT TO CEASE USING TO END THE EVENT. NO WATERWAY EFFECTED. A WSSC CONTRACT PLUMBER SNAKED THE PROPERTY LINE CLEANOUT 90' AND RELIEVED A HARD UNKNOWN OBSTRUCTION AT 75' OFF PROPERTY.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES