



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3285426-073-2023
3287922-118-2023

MDE OFFICIAL CONTACTED: JOANNE HOHMAN

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 09/17/2023 AT 04:32PM

WORK ORDER(S): 3287922 3287912

EST DATE AND TIME SSO BEGAN: 09/17/2023 08:48AM DURATION: 4.45 HRS
DATE AND TIME SSO ENDED: 09/17/2023 01:15PM

SOURCE-OVERFLOWING MH MH10064081 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 12501 WHITE DR 20904
COUNTY/PAGE/GRID: M 5286 J01 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 267 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 081M OVERFLOWING ONTO THE
SURROUNDING GRASS. THE CREW JETTED FROM MANHOLE 012M TO 082M, FOR
424FT, AND RELIEVED A SOFT UNKNOWN BLOCKAGE TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER DISCOLORATION

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ADDRESS ORIGINALLY REPORTED AS 12500 WHITE DRIVE

SIGNS POSTED: 6 POST DATE: 09/17/2023