



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3297120-118-2023

MDE OFFICIAL CONTACTED: AMANDA GLASSMAN

DATA CALLED IN BY: MARVIN BAILEY DATE: 10/19/2023 AT 06:50PM

WORK ORDER(S): 3297120 3297107

EST DATE AND TIME SSO BEGAN: 10/19/2023 12:45PM DURATION: 4.25 HRS
DATE AND TIME SSO ENDED: 10/19/2023 05:00PM

SOURCE-OVERFLOWING MH SS13016097 WATER BODY AFFECTED-MUDDY BRANCH

CLOSEST STREET ADDRESS: 9838 MAHOGANY DR 20878
COUNTY/PAGE/GRID: M 5163 H02 TOWN/CITY: GAITHERSBURG

CAUSE: ROOTS EST OVERFLOW VOLUME: 765 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 097M OVERFLOWING 3GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A STORM DRAIN THAT OUTFALLS INTO MUDDY BRANCH. THE CREW JETTED FROM MANHOLE 096M TO MANHOLE 097M, A TOTAL OF 102', REMOVING A HEAVY ROOT BLOCKAGE IN THE CHANNEL OF MANHOLE 096M, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW WASHED DOWN THE SIDEWALK AND SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 6 POST DATE: 10/19/2023