



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3301971-118-2023

MDE OFFICIAL CONTACTED: JOANNE HOHMAN#151302

DATA CALLED IN BY: ELBE L DAVIS

DATE: 11/06/2023 AT 06:57PM

WORK ORDER(S): 3301971 3301970

EST DATE AND TIME SSO BEGAN: 11/06/2023 04:00PM DURATION: 1.00 HRS

DATE AND TIME SSO ENDED: 11/06/2023 05:00PM

SOURCE-OVERFLOWING MH MH21996206 WATER BODY AFFECTED-MATTAWOMAN

CLOSEST STREET ADDRESS: 7102 ENGLISH POINT LN 20613

COUNTY/PAGE/GRID: P 5998 J03 TOWN/CITY: BRANDYWINE

CAUSE: GREASE EST OVERFLOW VOLUME: 60 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 206M OVERFLOWING APPROXIMATELY 1GPM, INTO A NEARBY STORM DRAIN THAT OUTFALLS TO A TRIBUTARY OF MATTAWOMAN CREEK. THE CREW JETTED FROM MANHOLE 205M TO 206M, A TOTAL OF 78FT, AND HIT AND RELIEVED A HEAVY GREASE AND DEBRIS OBSTRUCTION AT 57FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW FLUSHED DEBRIS BACK INTO THE MANHOLE AND THOROUGHLY WASHED DOWN THE STREET.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 7100 DESERT PEACE COURT.

SIGNS POSTED: 2 POST DATE: 11/07/2023