



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3302884-073-2023

MDE OFFICIAL CONTACTED: KENDRA DUKES

DATA CALLED IN BY: MARVIN BAILEY

DATE: 11/11/2023 AT 11:05AM

WORK ORDER(S): 3302884 3302825

EST DATE AND TIME SSO BEGAN: 11/10/2023 11:12AM DURATION: 1.63 HRS

DATE AND TIME SSO ENDED: 11/10/2023 12:50PM

SOURCE-WSSC CONTRACTOR'S BYPASS HOSE CUST ACCT: 00125777300 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 5015

SUITLAND RD

20744

COUNTY/PAGE/GRID: P 5650 C05

TOWN/CITY: SUITLAND

CAUSE: DAMAGED BY OTHERS

EST OVERFLOW VOLUME:

49 GAL

UPON ARRIVAL, THE CREW FOUND A HOLE IN THE WSSC CONTRACTORS BYPASS HOSE THAT HAD BEEN IN PLACE FOR ONGOING REPAIRS TO SS11046048. THE BYPASS HOSE WAS LEAKING AT APPROXIMATELY 0.5GPM, ONTO THE GRASSY AREA AROUND THE HOSE AND INTO A TRIBUTARY OF BROAD CREEK. THE WSSC CONTRACTOR REPLACED THE HOSE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED FROM A BYPASS SYSTEM AND IS NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA NEAR THE LEAKING HOSE.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

THIS EVENT DATE WAS ORIGINALLY REPORTED AS 11-11-2023.

SIGNS POSTED: 2 POST DATE: 11/10/2023